

155-163-13

ADDENDUM NO. 1

The Architect/ Engineer issues this addendum, applicable to the above named project, to all known Contractors before receipt of proposal.

This addendum includes Item Number 1-1 thru 1-5. This addendum item shall be fully incorporated into the Bidding/Contract Documents and have the same force and effect as though originally included.

The Bidder shall acknowledge receipt of this Addendum No. 1 on the Bid Proposal Form in the place provided.

GENERAL

Item 1-1: List of Pre-Bid Attendees

Attached is a list of Pre-Bid Attendees.

MECHANICAL

Drawings

Item 1-2: Sheets M1.01 – New Mechanical Plan

Provide bird screen (with min. ½" square openings) over the sealed combustion air intake opening on the bottom of the 45 degree elbow down in the area well.

Item 1-3: Sheets M1.01 – New Mechanical Plan

Reference New Mechanical Plan Note #3: The corridor boiler Emergency Power Off (EPO) sign type, appearance and lettering to match all other public signs located in the corridors of Building 1526. Coordinate these signs with Donna Necas at The Sign Post, phone # 402-464-3136.

Item 1-4: Sheets M2.01 – Mechanical Schedule and Schematic

Add Aerco Benchmark Model BMK 1000 with 20:1 turndown ratio to the approved equal boiler manufacturers. Note: the only approved flue vent outlet material to be AL29-4C as specified.

ELECTRICAL

Specifications

Item 1-5: Section 260000 – Electrical Work

Revise paragraph 13.3 to read as follows:

"Joints. All joints shall be compression type, and shall be made up mechanically secure and snug so as to take continuous current-carrying electrical contacts."

END OF ADDENDUM NO. 1



Meeting Sign-In Sheet

8-22-13

[illegible]

1010 Lincoln Mall, Suite 200
Lincoln, NE 68508-2883 402 477.9291 Fax 402 477.6542

www.clarkenersen.com
Lincoln, Nebraska • Kansas City, Missouri